


GAS BALL VALVES

PIPE THREAD x FLARE

Use:	To be installed at the end of the gas supply piping, for use in conjunction with an appliance connector. Valve is used for maintenance of the appliance and emergency appliance gas shut down. A gas valve is required within six feet of an appliance per National Fuel Gas Code.												
Operation:	Quarter turn of handle from full open to full closed.												
Operating Pressure:	1/2 psi maximum												
Operating Temperature:	See Below												
Material Specifications:	Body - Forged C36000 brass Retainer - Forged C36000 brass Ball - Chromium-plated C36000 brass Seats - Pure PTFE (same composition as Teflon*) Stem - C38000 extruded brass O-Ring - Viton (high temperature rubber) Handle - Aluminum SAE 384.2/383 Screw - Zinc-plated steel												
Flow Capacity:	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="text-align: right;">Min. Capacity, Btu/Hr,</td> </tr> <tr> <td>Outlet Connection Size:</td> <td style="text-align: right;">.64 Sp. Gr., 1,000 Btu/ft.³ gas</td> </tr> <tr> <td>(Nominal Tube O.D.)</td> <td style="text-align: right;">3" Water Column Pressure Drop =</td> </tr> <tr> <td style="padding-left: 20px;">3/8"</td> <td style="text-align: right;">50,000</td> </tr> <tr> <td style="padding-left: 20px;">1/2"</td> <td style="text-align: right;">100,000</td> </tr> <tr> <td style="padding-left: 20px;">5/8"</td> <td style="text-align: right;">130,000</td> </tr> </table>		Min. Capacity, Btu/Hr,	Outlet Connection Size:	.64 Sp. Gr., 1,000 Btu/ft. ³ gas	(Nominal Tube O.D.)	3" Water Column Pressure Drop =	3/8"	50,000	1/2"	100,000	5/8"	130,000
	Min. Capacity, Btu/Hr,												
Outlet Connection Size:	.64 Sp. Gr., 1,000 Btu/ft. ³ gas												
(Nominal Tube O.D.)	3" Water Column Pressure Drop =												
3/8"	50,000												
1/2"	100,000												
5/8"	130,000												
Designed and Manufactured In Accordance With:	ANSI Z21.15 - CGA 9.1 [rating 1/2 psi; -40°F to 125°F] CSA Requirement 3-88 [rating 5 psi; 32°F to 125°F] CGA Requirement CR91-002 [rating 2 or 5 psi; -40°F to 125°F]												
Approvals/Listings:	CSA File #204-593* NYC: MEA-344-98-E												

- AGA and CGA certification marks replaced with CSA mark starting June, 2000.



This technical product data sheet and all information contained herein is the confidential and exclusive property of BrassCraft Manufacturing, and shall not be disclosed to others without the written consent of BrassCraft. This technical product data sheet must be returned to BrassCraft if requested.

Tech. Product Data Sheet Number	© 2006 BrassCraft Mfg.	Revision Level
800.14	Page 1 of 1	(B)